

·BS· unit installation

m [kg]	Amin [m ²]			m [kg]	Amin [m ²]		
	All other floors (-a-)		Lowest underground floor (-b-)		All other floors (-a-)		Lowest underground floor (-b-)
	No safety measure (-c-)	External alarm (-d-)	No safety measure (-c-)		No safety measure (-c-)	External alarm (-d-)	No safety measure (-c-)
5	16	15	16	35	207	104	207
6	23	18	23	36	213	107	213
7	31	21	31	37	219	110	219
8	41	24	41	38	225	113	225
9	51	27	51	39	231	115	231
10	59	30	59	40	237	118	237
11	65	33	65	41	243	121	243
12	71	36	71	42	249	124	249
13	77	38	77	43	-	127	-
14	83	41	83	44	-	130	-
15	89	44	89	45	-	133	-
16	95	47	95	46	-	136	-
17	101	50	101	47	-	139	-
18	107	53	107	48	-	142	-
19	113	56	113	49	-	145	-
20	118	59	118	50	-	148	-
21	124	62	124	51	-	151	-
22	130	65	130	52	-	154	-
23	136	68	136	53	-	157	-
24	142	71	142	54	-	160	-
25	148	74	148	55	-	163	-
26	154	77	154	56	-	166	-
27	160	80	160	57	-	169	-
28	166	83	166	58	-	172	-
29	172	86	172	59	-	175	-
30	178	89	178	60	-	178	-
31	184	92	184	61	-	181	-
32	190	95	190	62	-	184	-
33	195	98	195	63	-	187	-
34	201	101	201	64	-	190	-