

RXYA-A

RYMA-A

Recommended indoor units for ·RXYA*A* + RYMA*A*· outdoor units

·· HP	8	10	12	13	14	16	18	20
	4xFXSA50	4xFXSA63	6xFXSA50	3xFXSA50 3xFXSA63	1xFXSA50 5xFXSA63	4xFXSA63 2xFXSA80	3xFXSA50 5xFXSA63	8xFXSA63

For multi outdoor units >16HP-, the recommended amount of indoor units is the sum of the indoor units defined for a single outdoor unit.
For details about the allowed combinations, see the engineering databook.

Appropriate indoor units for ·RXYA*A* + RYMA*A*· outdoor units

Covered by ·ENER LOT21·

- FXFA20-25-32-40-50-63-80-100-125
- FXZA15-20-25-32-40-50
- FXSA15-20-25-32-40-50-63-80-100-125-140
- FXDA10-15-20-25-32-40-50-63
- FXAA15-20-25-32-40-50-63
- FXMA50-63-80-100-125-200-250
- FXHA32-50-63-100
- FXUA50-71-100
- FXKA20-25-32-40-50-63
- FXNA20-25-32-40-50-63

Outside the scope of ·ENER LOT21·

- EKVDX32-50-80-100
- EKEXVA50-63-80-100-125-140-200-250-300-350-400-450-500 + EKEACBVE
- CYAS100*80, CYAS150*80, CYAS200*100, CYAS250*140
- CYAM100*80, CYAM150*80, CYAM200*100, CYAM250*140
- CYAL100*125, CYAL150*200, CYAL200*250, CYAL250*250