

Requirements for R32 units

To comply with the requirements of enhanced tightness refrigerating systems of the IEC 60335-2-40:2022, this system is equipped with an alarm in the remote controller and shut-off valves in the ·SV· unit.

These safety measures are installation specific and can be determined using the requirements mentioned in the outdoor unit manual.

The ·SV· unit is prearranged for a ventilated enclosure as countermeasure.

Outdoor unit installation

The outdoor unit has to be installed outside. For indoor installation of the outdoor unit, additional measures can be necessary to comply with the applicable legislation.

Indoor unit installation

The total amount of refrigerant in the system shall be less than or equal to the maximum allowed total refrigerant amount.

The maximum allowed total refrigerant amount depends on the area of the rooms being served by the system and the rooms in the lowest underground floor.

Note: The total refrigerant charge amount in the system MUST always be lower than 79.8 [kg].

Depending on the smallest room size in which the indoor unit is installed/conditioning and the total amount of refrigerant in the system, different safety measures can be applied.

Follow the flowchart. Details are described in the manual of the outdoor unit.

Use the graph or table ·1· to determine the required safety measures for the indoor unit.

Note: If the installation height is more than 2.2 m, different boundaries for the applicable safety measures can apply.

To know which safety measure is required in case the installation height is more than 2.2 m, refer to VRV Xpress (<https://vrvxpress.daikin.eu/>).