

Recommended indoor units for ·RXYQ*T* / RYYQ*T* / RYMQ*T*· outdoor units

HP	8	10	12	14	16	18	20
	4xFXM50	4xFXM63	6xFXM50	1xFXM50 5xFXM63	4xFXM63 2xFXM80	3xFXM50 5xFXM63	2xFXM50 6xFXM63

For multi outdoor units >16HP, the recommended amount of indoor units is the sum of the indoor units defined for a single outdoor unit.

For details about the allowed combinations, see the engineering databook.

Appropriate indoor units for ·RXYQ*T* / RYYQ*T* / RYMQ*T*· outdoor units

Covered by ·ENER LOT21·

- FXFQ20-25-32-40-50-63-80-100-125
- FXZQ15-20-25-32-40-50
- FXCQ20-25-32-40-50-63-80-125
- FXKQ25-32-40-63
- FXDQ15-20-25-32-40-50-63
- FXSQ15-20-25-32-40-50-63-80-100-125-140
- FXMQ50-63-80-100-125-200-250
- FXAQ15-20-25-32-40-50-63
- FXHQ32-63-100
- FXUQ71-100
- FXNQ20-25-32-40-50-63
- FXLQ20-25-32-40-50-63

Covered by ·ENER LOT10·

- FTXG25-35-50
- FTXS20-25-35-42-50-60-71
- CTXS15-35
- FLXS25-35-50-60
- FVXS25-35-50
- FVXG25-35-50

Outside the scope of ·ENER LOT21·

- EKEXV50-63-80-100-125-140-200-250-400-500 + EKEQM / EKEQF
- HXY080-125
- VKM50-80-100
- CYVS100-150-200-250
- CYVM100-150-200-250
- CYVL100-150-200-250