

# VRV4

## Heat pump

### Indoor unit combination restrictions

(2/2)

Combination table	RYYQ*	RYYQ*	RXYQ* RXMLQ* RXYLQ*	RXYQ* RXMLQ* RXYLQ*
	Single continuous heating	Multi continuous heating	Single non-continuous heating	Multi non-continuous heating
·VRV* DX· indoor unit	O	O	O	O
·RA DX· indoor unit	O	X	O	X
Hydrobox unit	O	O <sub>1</sub>	O	O <sub>1</sub>
Air handling unit (AHU) <sup>(2)</sup>	O	O	O	O

O: Allowed

X: Not allowed

Notes

- O<sub>1</sub>
  - Available upon request through the ·SPN· procedure.
- The following units are considered AHUs:
  - ·(EKEXV + EKEQ(MA/FA)) / (EKEXVA +EKEACBVE) + AHU· coil
  - ·Biddle· air curtain
  - ·FXMQ\_MF· units