

VRV4
Heat pump
Indoor unit combination restrictions
(2/2)

Combination table	RYYQ*	RYYQ*	RXYQ* RXMLQ* RXYLQ*	RXYQ* RXMLQ* RXYLQ*
	Single continuous heating	Multi continuous heating	Single non-continuous heating	Multi non-continuous heating
VRV* DX indoor unit	O	O	O	O
RA DX indoor unit	O	X	O	X
Hydrobox unit	O	O ₁	O	O ₁
Air handling unit (AHU) ⁽²⁾	O	O	O	O

O: Allowed

X: Not allowed

Notes

- O₁**
- Available upon request through the SPN procedure.
- (2) The following units are considered AHUs:
→ EKEXV + EKEQ(MA/FA) + AHU coil
→ Biddle air curtain
→ FXMQ_MF units