

Recommended indoor units for ·RXYQQ*U*· outdoor units

· HP	8	10	12	14	16	18	20
	4xFXM050	4xFXM063	6xFXM050	1xFXM050 5xFXM063	4xFXM063 2xFXM080	3xFXM050 5xFXM063	2xFXM050 6xFXM063

For multi outdoor units >16HP, the recommended amount of indoor units is the sum of the indoor units defined for a single outdoor unit.
For details about the allowed combinations, see the engineering databook.

Appropriate indoor units for ·RXYQQ*U*· outdoor units

Covered by ·ENER LOT21·

- FXFQ20-25-32-40-50-63-80-100-125
- FXZQ15-20-25-32-40-50
- FXCQ20-25-32-40-50-63-80-125
- FXKQ25-32-40-63
- FXDQ15-20-25-32-40-50-63
- FXSQ15-20-25-32-40-50-63-80-100-125-140
- FXMQ50-63-80-100-125-200-250
- FXAQ15-20-25-32-40-50-63
- FXHQ32-63-100
- FXUQ71-100
- FXNQ20-25-32-40-50-63
- FXLQ20-25-32-40-50-63

Outside the scope of ·ENER LOT21·

- EKEXV50-63-80-100-125-140-200-250-400-500 + EKEQM / EKEQF
- VKM50-80-100
- FXYBP20-25K7V19
- FXYSP20-25-32-40-50-63-80-100-125KA7V19
- FXYMP40-50-63-80-100-125-200-250KV1
- FXYCP20-25-32-40-50-63-80-125K7V19
- FXYFP20-25-32-40-50-63-80-100-125KB7V19
- FXYKP25-32-40-63KV1
- FXYHP32-63-100KVE9
- FXYLP20-25-32-40-50-63KV19
- FXYLMP20-25-32-40-50-63KV1
- FXYAP20-25-32-40-50-63KV19