

RXYSQ-TY1

RXYSQ-TY9

RXYSQ-TV9

RXYSQ-TV1

Recommended indoor units for ·RXYSQ*T* AND RXYSCQ*T*· outdoor units

· HP	4	5	6	8	10	12
	3xFXSQ25 1xFXSQ32	4xFXSQ32	2xFXSQ32 2xFXSQ40	4xFXMQ50	4xFXMQ63	6xFXMQ50

For details about the allowed combinations, see the engineering databook.

Appropriate indoor units for ·RXYSQ*T* AND RXYSCQ*T*· outdoor units

Covered by ·ENER LOT21·

- FXFQ20-25-32-40-50-63-80-100-125
- FXZQ15-20-25-32-40-50
- FXCQ20-25-32-40-50-63-80-125
- FXXQ25-32-40-63
- FXDQ15-20-25-32-40-50-63
- FXSQ15-20-25-32-40-50-63-80-100-125-140
- FXMQ50-63-80-100-125-200-250
- FXAQ15-20-25-32-40-50-63
- FXHQ32-63-100
- FXUQ71-100
- FXNQ20-25-32-40-50-63
- FXLQ20-25-32-40-50-63

Outside the scope of ·ENER LOT21·

- EKEXV50-63-80-100-125-140-200-250 + EKEQM / EKEQP
- VKM50-80-100
- CYVS100-150-200-250
- CYVM100-150-200-250
- CYVL100-150-200-250
- EKVDX32-50-80-100 + VAMJ8

Covered by ·ENER LOT10·

- FTXJ25-35-50
- FTXA20-25-35-42-50
- FTXM20N-25N-35N-42N-50N-60N-71N
- FTXM20R-25R-35R-42R-50R-60R-71R
- CTXM15N
- CTXM15R
- FLXS25-35-50-60
- FVXM25F-35F-50F
- FVXG25-35-50
- FNA25-35-50-60
- FDXM25-30-50-60
- FFA25-35-50-60
- FCAG35-50-60-71
- FHA35-50-60-71
- FBA35-50-60-71
- CVXM20A
- FVXM25A-35A-50A