

## Indoor unit installation

m [kg]	A <sub>min</sub> [m <sup>2</sup> ]			m [kg]	A <sub>min</sub> [m <sup>2</sup> ]		
	Lowest underground floor (·a·)		All other floors (·b·)		Lowest underground floor (·a·)		All other floors (·b·)
	No safety measure (·c·)	Safety alarm OR Natural ventilation (·d·)	No safety measure (·c·)		No safety measure (·c·)	Safety alarm OR Natural ventilation (·d·)	No safety measure (·c·)
5	15	10	10	43	128	85	85
6	18	12	12	44	131	87	87
7	21	14	14	45	134	89	89
8	24	16	16	46	137	91	91
9	27	18	18	47	140	93	93
10	30	20	20	48	143	95	95
11	33	22	22	49	146	97	97
12	36	24	24	50	149	99	99
13	39	26	26	51	152	101	101
14	42	28	28	52	154	103	103
15	45	30	30	53	157	105	105
16	48	32	32	54	160	107	107
17	51	34	34	55	163	109	109
18	54	36	36	56	166	111	111
19	57	38	38	57	169	113	113
20	60	40	40	58	172	115	115
21	63	42	42	59	175	117	117
22	66	44	44	60	178	119	119
23	69	46	46	61	181	121	121
24	72	48	48	62	184	123	123
25	75	50	50	63	187	125	125
26	77	52	52	64	190	127	127
27	80	54	54	65	193	129	129
28	83	56	56	66	196	131	131
29	86	58	58	67	199	133	133
30	89	60	60	68	202	135	135
31	92	62	62	69	205	137	137
32	95	64	64	70	208	139	139
33	98	66	66	71	211	141	141
34	101	68	68	72	214	143	143
35	104	70	70	73	217	145	145
36	107	72	72	74	220	147	147
37	110	74	74	75	223	149	149
38	113	76	76	76	226	151	151
39	116	77	77	77	229	153	153
40	119	79	79	78	231	154	154
41	122	81	81	79	234	156	156
42	125	83	83	80	237	158	158