

## VRV4

### Heat pump

### Indoor unit combination restrictions

(2/2)

Combination table	RYYQ*	RYYQ*	RXYQ* RXMLQ* RXYLQ*	RXYQ* RXMLQ* RXYLQ*
	Single continuous heating	Multi continuous heating	Single non-continuous heating	Multi non-continuous heating
-VRV* DX- indoor unit	O	O	O	O
-RA DX- indoor unit	O	X	O	X
Hydrobox unit	O	O <sub>1</sub>	O	O <sub>1</sub>
Air handling unit (AHU) <sup>(2)</sup>	O	O	O	O

O: Allowed  
 X: Not allowed

Notes

- O<sub>1</sub>  
 - Available upon request through the -SPN- procedure.
- (2) The following units are considered AHUs:
  - -EKEV + EKEQ(MA/FA) + AHU- coil
  - -Biddle- air curtain
  - -FXMQ\_MF- units