

RYYQ-U RYMQ-U

Recommended indoor units for -RXYQ*U* / RYYQ*U* / RYMQ*U*- outdoor units

-- HP	8	10	12	14	16	18	20
	4xFXMQ50	4xFXMQ63	6xFXMQ50	1xFXMQ50 5xFXMQ63	4xFXMQ63 2xFXMQ80	3xFXMQ50 5xFXMQ63	2xFXMQ50 6xFXMQ63

For multi outdoor units ->16HP, the recommended amount of indoor units is the sum of the indoor units defined for a single outdoor unit.

For details about the allowed combinations, see the engineering databook.

Appropriate indoor units for -RXYQ*U* / RYYQ*U* / RYMQ*U*- outdoor units

Covered by -ENER LOT21-

FXFQ20-25-32-40-50-63-80-100-125
FXZQ15-20-25-32-40-50
FXCQ20-25-32-40-50-63-80-125
FXKQ20-25-32-40-50-63
FXDQ15-20-25-32-40-50-63
FXSQ15-20-25-32-40-50-63-80-100-125-140
FXMQ50-63-80-100-125-200-250
FXAQ15-20-25-32-40-50-63
FXHQ32-63-100
FXUQ71-100
FXNQ20-25-32-40-50-63
FXLQ20-25-32-40-50-63

Covered by -ENER LOT10-

FTXJ20-25-35-42-50
FTXA20-25-35-42-50
FLXS25-35-50-60
FVXG25-35-50
FTXM20-25-35-42-50-60-71
CVXM20
FVXM25-35-50

Outside the scope of -ENER LOT21-

EKEXV50-63-80-100-125-140-200-250-400-500 + EKEQM / EKEQF
EKEXVA 50-63-80-100-125-140-200-250-300+350+400+450+500 + EKEACBVE
HXY080-125
VKM50-80-100
CYVS100*80, CYVS150*80, CYVS200*100, CYVS250*140
CYAS100*80, CYAS150*80, CYAS200*100, CYAS250*140
CYVM100*80, CYVM150*80, CYVM200*100, CYVM250*140
CYAM100*80, CYAM150*80, CYAM200*100, CYAM250*140
CYVL100*125, CYVL150*200, CYVL200*250, CYVL250*250
CYAL100*125, CYAL150*200, CYAL200*250, CYAL250*250
EKVDX32-50-80-100 + VAMJ8

3D118461G