

VRV4
Heat pump
Indoor unit combination restrictions
(2/2)

Combination table	RYYQ*	RYYQ*	RXYQ* RXMLQ* RXYLQ*	RXYQ* RXMLQ* RXYLQ*
	Single continuous heating	Multi continuous heating	Single non-continuous heating	Multi non-continuous heating
·VRV* DX· indoor unit	O	O	O	O
·RA DX· indoor unit	O	X	O	X
Hydrobox unit	O	O ₁	O	O ₁
Air handling unit (AHU) (2)	O	O	O	O

O: Allowed
X: Not allowed

Notes

1. O₁
 - Available upon request through the 'SPN' procedure.
2. The following units are considered AHUs:
 - ·(EKEV + EKEQ(MA/FA)) / (EKEVA +EKEACBVE) + AHU· coil
 - ·Biddle· air curtain
 - ·FXMQ_MF· units