

**Recommended indoor units for ·RXYQ\*U\* / RYYQ\*U\* / RYM\*U\*. outdoor units**

HP	8	10	12	14	16	18	20
	4xFXMQ50	4xFXMQ63	6xFXMQ50	1xFXMQ50 5xFXMQ63	4xFXMQ63 2xFXMQ80	3xFXMQ50 5xFXMQ63	2xFXMQ50 6xFXMQ63

For multi outdoor units >16HP, the recommended amount of indoor units is the sum of the indoor units defined for a single outdoor unit.  
 For details about the allowed combinations, see the engineering databook.

**Appropriate indoor units for ·RXYQ\*U\* / RYYQ\*U\* / RYM\*U\*. outdoor units**

**Covered by ·ENER LOT21·**

FXFQ20-25-32-40-50-63-80-100-125  
 FXZQ15-20-25-32-40-50  
 FXCQ20-25-32-40-50-63-80-125  
 FXKQ25-32-40-63  
 FXDQ15-20-25-32-40-50-63  
 FXSQ15-20-25-32-40-50-63-80-100-125-140  
 FXMQ50-63-80-100-125-200-250  
 FXAQ15-20-25-32-40-50-63  
 FXHQ32-63-100  
 FXUQ71-100  
 FXNQ20-25-32-40-50-63  
 FXLQ20-25-32-40-50-63

**Covered by ·ENER LOT10·**

FTXJ25-35-50  
 FTXM20-25-35-42-50-60-71  
 CTXM15  
 FLXS25-35-50-60  
 FVXM25-35-50  
 FVXG25-35-50

**Outside the scope of ·ENER LOT21·**

EKEXV50-63-80-100-125-140-200-250-400-500 + EKEQM / EKEQF  
 HXY080-125  
 VKM50-80-100  
 CYVS100-150-200-250  
 CYVM100-150-200-250  
 CYVL100-150-200-250