

SB.RKXYQ5TA

VRV4-i
Heat pump
Option list

		SB.RKXYQ5TA	
Nr.	Item	Heat exchanger unit	Compressor unit
I.	Refnet header	KHRQ22M29H	
II.	Refnet joint	KHRQ22M20T	
III.	Refnet joint	KHRQ22M32T9	
1a.	Cool/heat selector (switch)	-	KRC19-26
1b.	Cool/heat selector (fixing box)	-	KIB111A
1c.	Cool/heat selector (cable)	-	-
1d.	Cool/heat selector (PCB)	-	BRP2A81
2.	VRV configurator	-	EKPCCAB*
3.	Demand PCB	DTA104A61/62*	
4.	Drain pan heater	EKDPH1RDX	-

Notes

1. All options are kits.
2. To mount option 1a, option 1b is required.
3. VRV4-i SHP: To operate the cool/heat selector function, options 1a and 1d are both required.
4. If the outdoor temperature can drop below -7°C for more than 24 hours, it is recommended to install drain pan heater kit EKDPH1RDX.