

		Indoor air temperature													
Unit size	Fan speed	14,0 [°C WB]		16,0 [°C WB]		18,0 [°C WB]		19,0 [°C WB]		20,0 [°C WB]		22,0 [°C WB]		24,0 [°C WB]	
		20,0 [°C DB]		23,0 [°C DB]		26,0 [°C DB]		27,0 [°C DB]		28,0 [°C DB]		30,0 [°C DB]		32,0 [°C DB]	
		TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
20	H	1,3	1,0	1,6	1,2	2,0	1,5	2,2	1,5	2,4	1,6	2,8	1,7	3,3	1,8
	M	Correction factor -0.86 × H-													
	L	Correction factor -0.77 × H-													
25	H	1,6	1,4	2,1	1,6	2,6	1,9	2,8	2,0	3,1	2,1	3,6	2,2	4,2	2,4
	M	Correction factor -0.89 × H-													
	L	Correction factor -0.79 × H-													
32	H	2,1	1,7	2,7	2,1	3,3	2,4	3,6	2,5	3,9	2,6	4,7	2,8	5,5	3,0
	M	Correction factor -0.86 × H-													
	L	Correction factor -0.75 × H-													
40	H	2,6	2,1	3,3	2,5	4,1	3,0	4,5	3,1	4,9	3,2	5,8	3,4	6,8	3,7
	M	Correction factor -0.87 × H-													
	L	Correction factor -0.76 × H-													
50	H	3,3	2,7	4,2	3,2	5,1	3,7	5,6	3,9	6,1	4,0	7,2	4,3	8,4	4,6
	M	Correction factor -0.84 × H-													
	L	Correction factor -0.71 × H-													
63	H	4,2	3,4	5,3	4,1	6,5	4,7	7,1	4,9	7,7	5,1	9,1	5,5	10,5	5,7
	M	Correction factor -0.82 × H-													
	L	Correction factor -0.66 × H-													

Notes

- 1) TC: Total capacity [kW]
SHC: Sensible heat capacity [kW]
H: High
M: Medium
L: Low

2) Outdoor temperature -35°C DB

Heating

		Indoor air temperature					
Unit size	Fan speed	16,0 [°C DB]	18,0 [°C DB]	20,0 [°C DB]	21,0 [°C DB]	22,0 [°C DB]	24,0 [°C DB]
		TC	TC	TC	TC	TC	TC
20	H	2,9	2,7	2,5	2,4	2,3	2,1
	M	Correction factor -0.84 × H-					
	L	Correction factor -0.72 × H-					
25	H	3,7	3,5	3,2	3,1	3,0	2,7
	M	Correction factor -0.84 × H-					
	L	Correction factor -0.72 × H-					
32	H	4,6	4,3	4,0	3,8	3,7	3,4
	M	Correction factor -0.85 × H-					
	L	Correction factor -0.73 × H-					
40	H	5,8	5,4	5,0	4,8	4,6	4,2
	M	Correction factor -0.84 × H-					
	L	Correction factor -0.72 × H-					
50	H	7,3	6,8	6,3	6,1	5,8	5,3
	M	Correction factor -0.81 × H-					
	L	Correction factor -0.65 × H-					
63	H	9,2	8,6	8,0	7,7	7,4	6,8
	M	Correction factor -0.79 × H-					
	L	Correction factor -0.63 × H-					

Notes

- 1) TC: Total capacity [kW]
H: High
M: Medium
L: Low
- 2) Outdoor temperature -7°C DB / -6°C WB