VAM-J8

Available options for ·VAM*J8*· models

Item				Model				
				VAM350J8VEB	VAM500J8VEB	VAM650J8VEB	VAM800J8VEB VAM800J8VEB9 VAM800J8VEB8	VAM1000J8VEB VAM1000J8VEB9 VAM1000J8VEB8	VAM1500J8VEB VAM1500J8VEB9 VAM1500J8VEB8	VAM2000J8VEB VAM2000J8VEB9 VAM2000J8VEB8
Control systems	Remote control			BRC301B61						
	Remote control | Wired type			BRC1D52						
				BRC1E53A7 (1) / BRC1E53B7 (2) / BRC1E53C7 (3) / BRC1H52* / BRC1H82* / BRC1K*						
	Centralised control systems	Central remote control		DCS302C51						
		Unified ON/OFF controller		DCS301B51						
		iTouch Manager		DCM601A51						
		iTouch Controller		DCS601C51						
		iTab Controller		DCC601A51						
		Modbus ·DIII· adaptor		EKMBDXA7V1						
	Adaptor PCB	Wiring adaptor for electrical appendices		KRP2A51 + Installation box ·KRP1BA101·						
		For heaters		BRP4A50A						
		Mounting plate		- - - -		EKMP65VAM (5)	- - - -		EKMPVAM (4)	
Miscellaneous	Plenum chamber		Model	- - - -					EKPLEN200 (6)	
			Outside diameter [mm]						Ø350	
	High-efficiency filter (see note ·7·)		ePM10 70% (M6)	EKAFVJ50F6		EKAFVJ65F6	EKAFVJ100F6		EKAFVJ100F6 x 2	
			ePM1 60% (F7)	EKAFVJ50F7		EKAFVJ65F7	EKAFVJ100F7		EKAFVJ100F7 x 2	
			ePM1 70% (F8)	EKAFVJ50F8		EKAFVJ65F8	EKAFVJ100F8		EKAFVJ100F8 x 2	
CO2 Sensor				BRYMA65			BRYMA100		BRYMA200	

Notes

1. BRC1E53A7 Included languages are: English, German, French, Italian, Spanish, Portuguese, and Dutch.
2. BRC1E53B7 Included languages are: English, Czech, Croatian, Hungarian, Slovenian, Romanian, and Bulgarian.
3. BRC1E53C7 Included languages are: English, Russian, Greek, Turkish, Polish, Albanian, and Slovak.
4. To install an adaptor PCB on ·VAM1500J/VAM2000J· units, mounting plate ·EKMPVAM· is required.
5. To install an adaptor PCB on ·VAM650J· units, mounting plate ·EKMP65VAM· is required.
6. Plenum chamber to merge either ·2· air inlets or ·2· air outlets. Up to ·4· plenum chambers can be connected.
7. If you order 1 filter set, you can use it for either supply side or exhaust side. To provide both sides with filters, 2 filter sets are required.